



Notes:

- 1.) 24 VAC Must Be Connected So That All Ground Wires Remain Common.
- 2.) All Wiring To Be In Accordance With Local And National Electrical Codes and Specifications.
- 3.) The Local Loop May Have Up To 16 Zone Controllers Connected.
- 4.) All Communication Wiring To Be 18 Ga. Minimum, 2 Conductor Twisted Pair With Shield. Belden #82760 Or Equivalent.
- 5.) For Individual Component Wiring See Specific Component Wiring Diagram.
- 6.) It Is Recommended That All Controllers Address Switches Are Set Before Installation.

JOB NAME	
FILENAME	
035-18965-000-A-0602.CDR	
DATE: 06/28/02	DRAWN BY: B. CREWS
PAGE	DESCRIPTION:
1	Meridian Basic System Wiring Diagram